



#### LUMINAIRE REQUIREMENTS:

1. HOUSING – DIE-FORMED, COLD-ROLLED STEEL, WITH REINFORCEMENT RIBS FOR RIGIDITY. HIGHLY-REFLECTIVE PAINTED STEEL REFLECTORS WITH OPTIONAL UPLIGHT COMPONENT. OPTIONAL LENGTHS OF 2FT, 4FT OR 8FT AVAILABLE.
2. FINISH – MULTI-STAGE PHOSPHATE BONDING TREATMENT FINISHED WITH HIGH-REFLECTANCE, WHITE ENAMEL, PAINTED AFTER FABRICATION.
3. LIGHT SOURCE – LINEAR T8 FLUORESCENT TUBES WITH QUANTITY AND CHARACTERISTICS AS INDICATED IN LUMINAIRE SCHEDULE.
4. BALLAST – PROGRAMMED-START, CLASS P, THERMALLY-PROTECTED, HIGH POWER FACTOR (>0.9), ELECTRONIC TYPE WITH < 20% THD AND 'A' SOUND RATING.
5. CERTIFICATION – UL 1598, DAMP LOCATION, UL 924 WHEN EQUIPPED WITH EMERGENCY BATTERY BACK-UP.
6. MOUNTING – SURFACE ON CEILING OR SUSPENDED.
7. OPTIONS – WIRE GUARD, CHAIN, STEM OR SWIVEL STEM HANGERS.
8. THIS SKETCH IS A NON-PROPRIETARY GRAPHIC REPRESENTATION OF A LUMINAIRE THAT MAY MEET THE SPECIFICATION REQUIREMENTS. IT IS NOT INTENDED TO INDICATE A CERTAIN MANUFACTURER OR PREFERENCE.

## FLUORESCENT INDUSTRIAL STRIP

REVISED:

APRIL 2016

LIGHTING PLATE:

NL-8