

LUMINAIRE REQUIREMENTS:

- 1. HOUSING DIE—FORMED, COLD—ROLLED STEEL, WITH REINFORCEMENT RIBS FOR RIGIDITY; END CAPS SAME MATERIAL AS HOUSING, SECURED WITH TABS, SCREWS OR RIVETS. WHITE ENAMEL FINISH APPLIED AFTER FABRICATION. OPTIONAL LENGTHS OF 2 FT, 3 FT OR 4 FT.
- 2. LENS ACRYLIC PRISMATIC (CLEAR PRISMATIC PATTERN A12) OR WHITE OPAL, WITH MINIMUM THICKNESS OF 0.125 IN.
- 3. LIGHT SOURCE LINEAR T8, T5 OR T5HO FLUORESCENT TUBES WITH QUANTITY AND CHARACTERISTICS AS INDICATED IN LUMINAIRE SCHEDULE.
- 4. BALLAST PROGRAMMED—START, CLASS P, THERMALLY—PROTECTED, HIGH POWER FACTOR (>0.9), ELECTRONIC TYPE WITH <20% THD AND 'A' SOUND RATING.
- 5. CERTIFICATION UL 1598, DAMP LOCATION, UL 924 WHEN EQUIPPED WITH EMERGENCY BATTERY BACK—UP.
- 6. MOUNTING SURFACE ON WALL.
- 7. OPTIONS EMERGENCY BACK-UP. <10% THD BALLAST. DOWNLIGHT COMPONENT ONLY.
- 8. THIS SKETCH IS A NON-PROPRIETARY GRAPHIC REPRESENTATION OF A LUMINAIRE THAT MAY MEET THE SPECIFICATION REQUIREMENTS. IT IS NOT INTENDED TO INDICATE A CERTAIN MANUFACTURER OR PREFERENCE.

WALL MOUNTED FLUORESCENT

REVISED: APRIL 2016 | LIGHTING PLATE: NL-10