



LUMINAIRE REQUIREMENTS:

1. HOUSING – FIBERGLASS OR FIBERGLASS–REINFORCED POLYESTER OUTER HOUSING, WITH ALUMINUM COMPONENT TRAY. OPTIONAL LENGTHS OF 4 FT OR 8 FT.
2. LENS – IMPACT–RESISTANT ACRYLIC OR OPTIONAL POLYCARBONATE, WITH CONTINUOUS CLOSED–CELL POLYURETHANE GASKET, SECURED WITH STAINLESS STEEL OR OPTIONAL POLYCARBONATE LATCHES.
3. LIGHT SOURCE – LINEAR T8, T5 OR T5HO FLUORESCENT TUBES WITH QUANTITY AND CHARACTERISTICS AS INDICATED IN LUMINAIRE SCHEDULE.
4. BALLAST – PROGRAMMED–START, CLASS P, THERMALLY–PROTECTED, HIGH POWER FACTOR (>0.9), ELECTRONIC TYPE WITH <20% THD AND 'A' SOUND RATING.
5. CERTIFICATION – UL 1598, WET LOCATION (IP65, IP66, IP67), UL 924 WHEN EQUIPPED WITH EMERGENCY BATTERY BACK–UP.
6. MOUNTING – SURFACE–MOUNTED OR SUSPENDED FROM CEILING.
7. OPTIONS – EMERGENCY BACK–UP, INTEGRAL MOTION SENSOR, DIMMING.
8. THIS SKETCH IS A NON–PROPRIETARY GRAPHIC REPRESENTATION OF A LUMINAIRE THAT MAY MEET THE SPECIFICATION REQUIREMENTS. IT IS NOT INTENDED TO INDICATE A CERTAIN MANUFACTURER OR PREFERENCE.

FLUORESCENT ENCLOSED AND GASKETED

REVISED:

APRIL 2016

LIGHTING PLATE:

NL–12