



LUMINAIRE REQUIREMENTS:

1. HOUSING – DIE-CAST, COLD-ROLLED STEEL OR EXTRUDED ALUMINUM BODY WITH REINFORCEMENT RIBS FOR RIGIDITY AND DIE CAST ALUMINUM END CAPS. OPTIONAL LENGTHS OF 4 FT OR 8 FT.
2. FINISH – BAKED-ON POWDER COATED MATTE WHITE OR METALLIC SILVER WITH OPTIONAL CUSTOM COLORS.
3. LOUVERS – SEMI-SPECULAR ANODIZED ALUMINUM WITH OPTIONAL ACRYLIC LENSES FOR DIFFUSE DOWNWARD LIGHT. OPTIONAL UPWARD AND/OR DOWNWARD LIGHT DISTRIBUTIONS.
4. LIGHT SOURCE – LINEAR T8, T5 OR T5HO FLUORESCENT TUBES WITH QUANTITY AND CHARACTERISTICS AS INDICATED IN LUMINAIRE SCHEDULE.
5. BALLAST – PROGRAMMED-START, CLASS P, THERMALLY-PROTECTED, HIGH POWER FACTOR (>0.9), ELECTRONIC TYPE WITH <20% THD AND 'A' SOUND RATING.
6. CERTIFICATION – UL 1598, DAMP LOCATION, UL 924 WHEN EQUIPPED WITH EMERGENCY BATTERY BACK-UP.
7. MOUNTING – SUSPENDED FROM HARD OR ACOUSTICAL TILE CEILING.
8. OPTIONS – VARIOUS UPLIGHT/DOWNLIGHT COMBINATIONS, DIMMING BALLAST, EMERGENCY BATTERY BACK-UP, VARIOUS DIFFUSE LENSES.
9. THIS SKETCH IS A NON-PROPRIETARY GRAPHIC REPRESENTATION OF A LUMINAIRE THAT MAY MEET THE SPECIFICATION REQUIREMENTS. IT IS NOT INTENDED TO INDICATE A CERTAIN MANUFACTURER OR PREFERENCE.

FLUORESCENT LINEAR PENDANT

REVISED:

APRIL 2016

LIGHTING PLATE:

NL-14