



LUMINAIRE REQUIREMENTS:

1. HOUSING – STEEL FRAME AND VERTICAL PENDANT FINISHED IN SATIN NICKEL OR CHROME. STAINLESS STEEL SUPPORT WIRES FROM TOP CEILING PLATE FOR BRACING AND SUPPORT.
2. BOWL – TRANSLUCENT ACRYLIC, FAUX ALABASTER, WHITE OR DIFFUSED GLASS. OTHER OPTIONS AVAILABLE
3. LIGHT SOURCE – T5 LONG TWIN TUBE OR 4-PIN COMPACT FLUORESCENT WITH QUANTITY AND CHARACTERISTICS AS INDICATED IN LUMINAIRE SCHEDULE.
4. BALLAST – PROGRAMMED-START, CLASS P, THERMALLY-PROTECTED, HIGH POWER FACTOR (>0.9), ELECTRONIC TYPE WITH <20% THD AND 'A' SOUND RATING.
5. CERTIFICATION – UL 1598, DAMP LOCATION, UL 924 WHEN EQUIPPED WITH EMERGENCY BATTERY BACK-UP.
6. MOUNTING – SUSPENDED FROM HARD OR ACOUSTICAL TILE CEILING.
7. OPTIONS – VARIOUS BOWL MATERIALS AND FINISHES, HARDWARE FINISHES, METAL MATERIALS, AND EMERGENCY BACK-UP.
8. THIS SKETCH IS A NON-PROPRIETARY GRAPHIC REPRESENTATION OF A LUMINAIRE THAT MAY MEET THE SPECIFICATION REQUIREMENTS. IT IS NOT INTENDED TO INDICATE A CERTAIN MANUFACTURER OR PREFERENCE.

ROUND FLUORESCENT PENDANT

REVISED:

APRIL 2016

LIGHTING PLATE:

NL-16