



LUMINAIRE REQUIREMENTS:

1. HOUSING – DIE-FORMED, COLD-ROLLED STEEL, WITH REINFORCEMENT RIBS FOR RIGIDITY; HIGH-REFLECTANCE WHITE ENAMEL FINISH APPLIED AFTER FABRICATION. OPTIONAL LENGTHS OF 2 FT OR 4 FT.
2. REFLECTOR – ASYMMETRICAL, LOW-IRRIDESCENT, SEMI-SPECULAR ANODIZED ALUMINUM OR HIGH-REFLECTANCE, WHITE ENAMEL PAINTED STEEL.
3. LIGHT SOURCE – LINEAR T8, T5, T5HO OR TT5 LONG TWIN TUBE FLUORESCENT TUBES WITH QUANTITY AND CHARACTERISTICS AS INDICATED IN LUMINAIRE SCHEDULE.
4. BALLAST – PROGRAMMED-START, CLASS P, THERMALLY-PROTECTED, HIGH POWER FACTOR (>0.9), ELECTRONIC TYPE WITH <20% THD AND 'A' SOUND RATING.
5. CERTIFICATION – UL 1598, DAMP LOCATION, UL 924 WHEN EQUIPPED WITH EMERGENCY BATTERY BACK-UP.
6. MOUNTING – RECESSED IN HARD OR ACOUSTICAL TILE CEILING.
7. OPTIONS – PERFORATED DIFFUSER, DIMMING BALLAST.
8. THIS SKETCH IS A NON-PROPRIETARY GRAPHIC REPRESENTATION OF A LUMINAIRE THAT MAY MEET THE SPECIFICATION REQUIREMENTS. IT IS NOT INTENDED TO INDICATE A CERTAIN MANUFACTURER OR PREFERENCE.

FLUORESCENT LINEAR WALL WASH

REVISED:

APRIL 2016

LIGHTING PLATE:

NL-18