



LUMINAIRE REQUIREMENTS:

1. HOUSING – CAST ALUMINUM OR DIE-CAST, COLD-ROLLED STEEL WITH BAKED-ON POLYESTER POWDER OR ENAMEL FINAL COAT.
2. REFRACTOR – TEARDROP TYPE, INJECTION-MOLDED, UV-STABILIZED ENCLOSED PRISMATIC ACRYLIC OR POLYCARBONATE MATERIAL DESIGNED FOR LOW GLARE OUTPUT.
3. LIGHT SOURCE – INDUCTION GENERATOR AND GLASS ENVELOPE WITH WATTAGE AND CHARACTERISTICS AS INDICATED IN LUMINAIRE SCHEDULE.
4. GENERATOR – INTEGRAL, HIGH-EFFICIENCY GENERATOR WITH MINIMUM 0.9 PF, OPERATING VOLTAGE OF 120-277V, THERMAL MANAGEMENT, < 20% TOTAL HARMONIC DISTORTION. ON-OFF CONTROL, STEP-DIMMABLE OR FULLY DIMMABLE AS INDICATED.
5. CERTIFICATION – UL 1598, DAMP OR OPTIONAL WET LOCATION.
6. MOUNTING – DIRECT JUNCTION BOX OR PENDANT FROM STRUCTURAL CEILING.
7. OPTIONS – POWER HOOK AND CORD WITH TWIST-LOCK RECEPTACLE, WET LOCATION RATING, WIRE GUARD, TYPE V OR ASYMMETRICAL DISTRIBUTION.
8. THIS SKETCH IS A NON-PROPRIETARY GRAPHIC REPRESENTATION OF A LUMINAIRE THAT MAY MEET THE SPECIFICATION REQUIREMENTS. IT IS NOT INTENDED TO INDICATE A CERTAIN MANUFACTURER OR PREFERENCE.

INDUCTION LOW-BAY INDUSTRIAL

REVISED:

APRIL 2016

LIGHTING PLATE:

NL-26