

NOTE: THIS SKETCH IS A NON-PROPRIETARY GRAPHIC REPRESENTATION OF A LUMINAIRE THAT MAY MEET THE SPECIFICATION REQUIREMENTS. IT IS NOT INTENDED TO INDICATE A CERTAIN MANUFACTURER OR PREFERENCE.

## LUMINAIRE REQUIREMENTS:

- 1. HOUSING DIE—FORMED, COLD ROLLED STEEL, WITH REINFORCEMENT RIBS FOR RIGIDITY; ENDCAPS SAME MATERIAL AS HOUSING, SECURED TABS, SCREWS, OR RIVETS. SIZE AS INDICATED IN LUMINAIRE SCHEDULE.
- 2. OPTICS ACRYLIC OR POLYCARBONATE LENS AS INDICATED IN LUMINAIRE SCHEDULE.
- 3. LIGHT SOURCE SOLID STATE LEDS, 3500K CCT UON, MINIMUM 80 CRI UON, AND MINIMUM EFFICACY OF 110 LUMENS/WATT UON. INITIAL LUMEN OUTPUT AS INDICATED IN LUMINAIRE SCHEDULE.
- 4. DRIVER REPLACEABLE, INTEGRAL, HIGH—EFFICIENCY DRIVER WITH MINIMUM 0.9 PF, OPERATING VOLTAGE OF 120–277V, THERMAL MANAGEMENT, AND < 20% THD. ON/OFF CONTROL AND FULLY DIMMABLE DOWN TO 10% MINIMUM OR AS INDICATED IN LUMINAIRE SCHEDULE.
- 5. CERTIFICATION UL LISTED FOR DRY OR DAMP LOCATION, ROHS COMPLIANT, DLC QUALIFIED. COMPLIES WITH IES LM79, LM80 AND TM21 TESTING STANDARDS.
- 6. MOUNTING SURFACE MOUNTED.
- 7. OPTIONS EMERGENCY BATTERY BACK-UP, INTEGRAL OCCUPANCY/VACANCY SENSOR, VARIOUS SIZE AND OUTPUT OPTIONS.

$\triangle$		
- L' L L L L L L L L L L L L L L L L L L	1 1 1 1	_ \
SURFACE	1 - 1 1	WRAPAROUND
	1 1 1 /	

REVISED: NOVEMBER 2020 LIGHTING PLATE: NL-3