



NOTE: THIS SKETCH IS A NON-PROPRIETARY GRAPHIC REPRESENTATION OF A LUMINAIRE THAT MAY MEET THE SPECIFICATION REQUIREMENTS. IT IS NOT INTENDED TO INDICATE A CERTAIN MANUFACTURER OR PREFERENCE.

#### LUMINAIRE REQUIREMENTS:

1. HOUSING – DIE CAST ALUMINUM FRAME AND HEAT SINK WITH ENAMELED FINISH. SIZE AS INDICATED IN LUMINAIRE SCHEDULE.
2. OPTICS – ACRYLIC OR POLYCARBONATE REFRACTIVE LENS. EDGE-LIT, LAMBERTIAN, NARROW, WIDE, OR ASYMMETRIC LIGHT DISTRIBUTION AS INDICATED IN LUMINAIRE SCHEDULE.
3. LIGHT SOURCE – SOLID STATE LEDS, 3500K CCT UON, MINIMUM 80 CRI UON, AND MINIMUM EFFICACY OF 75 LUMENS/WATT UON. INITIAL LUMEN OUTPUT AS INDICATED IN LUMINAIRE SCHEDULE.
4. DRIVER – REPLACEABLE, HIGH-EFFICIENCY DIMMABLE DRIVER WITH MINIMUM 0.9 PF, OPERATING VOLTAGE OF 120–277V, THERMAL MANAGEMENT, AND < 20% THD. ON-OFF CONTROL AND FULLY DIMMABLE DOWN TO 10% MINIMUM OR AS INDICATED IN LUMINAIRE SCHEDULE. INTEGRAL TO LUMINAIRE OR REMOTE-LOCATED IN ACCESSIBLE LOCATION.
5. CERTIFICATION – UL LISTED FOR DRY OR DAMP LOCATION, ROHS COMPLIANT, DLC QUALIFIED. COMPLIES WITH IES LM79, LM80 AND TM21 TESTING STANDARDS.
6. MOUNTING – PENDANT OR STEM MOUNTED WITH STAINLESS STEEL MOUNTING HARDWARE.
7. OPTIONS – EMERGENCY BATTERY BACK-UP, VARIOUS PROFILE DIMENSIONS AND RUN LENGTHS, AND VARIOUS CLEAR OR FROSTED POLYCARBONATE LENSES, BAFFLES, OR LOUVERS.

## DIRECT/INDIRECT LED PENDANT

REVISED:

NOVEMBER 2020

LIGHTING PLATE:

NL-6