



POLE TYPE	DIMENSIONS - FEET					
	"U"	"V"	"W"	"X"	"Y"	"Z"
XL-24 A	14	10	2	2	4	3.5
XL-24 B	20	16	2	2	4	3.5
XL-24 C	25	20	2	2	5	4.5
XL-24 D	30	25	2	2	5	4.5
XL-24 E	35	30	2	2	5	4.5
XL-24 F	40	33	2	2	7	6.5
XL-24 G	45	38	2	2	7	6.5

TAPERED OR STRAIGHT CONCRETE POLE. CROSS SECTIONAL SHAPE, COLOR AND FINISH (SMOOTH OR AGGREGATE) AS INDICATED.

WIRING HANDHOLE MINIMUM 2 1/2" X 5" CLEAR OPENING WITH COVER AND STAINLESS STEEL SCREWS.

TERMINATE CONDUITS INTERNALLY, ADJACENT TO HANDHOLE.

COMPACTED CLAY BACKFILL; SLOPE TO SURROUNDING FINISHED GRADE.

MINIMUM 3" X 5" CONDUIT OR CABLE ENTRANCE - 2 EACH AT 180 DEGREES.

BACKFILL FINE CRUSHED STONE AND PORTLAND CEMENT (8-1) DRY MIX COMPACTED IN 6" LAYERS.

COARSE GRAVEL SETTING BED:

- NOTES:
1. PROVIDE ANTI-ROTATIONAL DEVICE ON EACH POLE.
  2. COORDINATE TOTAL EPA WITH POLE SPECIFICATIONS.
  3. MODIFY DIMENSIONAL DATA FOR POLE BASE TO SUIT LOCAL CONDITIONS.

## DIRECT-SET CONCRETE POLE