



NOTE: THIS SKETCH IS A NON-PROPRIETARY GRAPHIC REPRESENTATION OF A LUMINAIRE THAT MAY MEET THE SPECIFICATION REQUIREMENTS. IT IS NOT INTENDED TO INDICATE A CERTAIN MANUFACTURER OR PREFERENCE.

#### LUMINAIRE REQUIREMENTS:

1. HOUSING – DIE-CAST ALUMINUM HOUSING WITH POWDER COAT FINISH.
2. OPTICS – INJECTION MOLDED OPTICS WITH TYPE I, II, III, IV, OR V DISTRIBUTIONS. BUG UPLIGHT RATING OF U0, WITH GLARE RATING AS DETERMINED BY LIGHTING ZONE INSTALLED.
3. LIGHT SOURCE – SOLID STATE LEDS, 3000K CCT U0N, MINIMUM 70 CRI U0N, AND MINIMUM EFFICACY OF 90 LUMENS/WATT U0N. INITIAL LUMEN OUTPUT AS INDICATED IN LUMINAIRE SCHEDULE.
4. DRIVER – REPLACEABLE, INTEGRAL, HIGH-EFFICIENCY DIMMABLE DRIVER WITH MINIMUM 0.9 PF, OPERATING VOLTAGE OF 120-277V, THERMAL MANAGEMENT, AND < 20% THD. ON-OFF CONTROL OR AS INDICATED IN LUMINAIRE SCHEDULE. MEETS ELEVATED 10KV/10KA REQUIREMENTS PER IEEE.
5. CERTIFICATION – UL LISTED FOR WET LOCATION, ROHS COMPLIANT. COMPLIES WITH IES LM79, LM80 AND TM21 TESTING STANDARDS.
6. MOUNTING – ARM-MOUNTED ON POLE.
7. OPTIONS – MOUNTING ARM LENGTH, LIGHT DISTRIBUTION, HOUSE-SIDE SHIELD, PHOTOCCELL, INTEGRAL MOTION SENSOR, AND ANSI 7-PIN RECEPTACLE.

## LED PEDESTRIAN LUMINAIRE

REVISED:

NOVEMBER 2020

LIGHTING PLATE:

XL-3