



NOTE: THIS SKETCH IS A NON-PROPRIETARY GRAPHIC REPRESENTATION OF A LUMINAIRE THAT MAY MEET THE SPECIFICATION REQUIREMENTS. IT IS NOT INTENDED TO INDICATE A CERTAIN MANUFACTURER OR PREFERENCE.

LUMINAIRE REQUIREMENTS:

1. HOUSING – DIE-CAST ALUMINUM HOUSING.
2. OPTICS – ALUMINUM REFLECTOR. BUG RATING AS INDICATED IN LUMINAIRE SCHEDULE.
3. LIGHT SOURCE – SOLID STATE LEDS, 3000K CCT UON, MINIMUM 80 CRI UON, AND MINIMUM EFFICACY OF 5 LUMENS/WATT UON. INITIAL LUMEN OUTPUT AS INDICATED IN LUMINAIRE SCHEDULE.
4. DRIVER – REPLACEABLE, INTEGRAL, HIGH-EFFICIENCY DIMMABLE DRIVER WITH MINIMUM 0.9 PF, OPERATING VOLTAGE OF 120-277V, THERMAL MANAGEMENT, AND < 20% THD. ON-OFF CONTROL AND FULLY DIMMABLE DOWN TO 10% MINIMUM OR AS INDICATED IN LUMINAIRE SCHEDULE.
5. CERTIFICATION – UL LISTED FOR WET LOCATION, ROHS COMPLIANT. COMPLIES WITH IES LM79, LM80 AND TM21 TESTING STANDARDS.
6. MOUNTING – CAVITY WALL CONSTRUCTION OR CONCRETE POUR CONSTRUCTION.
7. OPTIONS – LENSES, BODY SHAPE AND STYLE, AND LIGHT DISTRIBUTION.

LED EXTERIOR STEP LIGHT

REVISED:

NOVEMBER 2020

LIGHTING PLATE:

XL-7