



NOTE: THIS SKETCH IS A NON-PROPRIETARY GRAPHIC REPRESENTATION OF A LUMINAIRE THAT MAY MEET THE SPECIFICATION REQUIREMENTS. IT IS NOT INTENDED TO INDICATE A CERTAIN MANUFACTURER OR PREFERENCE.

#### LUMINAIRE REQUIREMENTS:

1. HOUSING – ALUMINUM HOUSING OR STAINLESS STEEL HOUSING.
2. OPTICS – DIFFUSE VANDAL-RESISTANT ACRYLIC LENS. BUG UPLIGHT RATING OF U0, WITH GLARE RATING AS DETERMINED BY LIGHTING ZONE INSTALLED.
3. LIGHT SOURCE – SOLID STATE LEDS, 3000K CCT UON, MINIMUM 80 CRI UON, AND MINIMUM EFFICACY OF 50 LUMENS/WATT UON. INITIAL LUMEN OUTPUT AS INDICATED IN LUMINAIRE SCHEDULE.
4. DRIVER – REPLACEABLE, INTEGRAL, HIGH-EFFICIENCY DIMMABLE DRIVER WITH MINIMUM 0.9 PF, OPERATING VOLTAGE OF 120 OR 277V, THERMAL MANAGEMENT, AND < 20% THD. ON-OFF CONTROL AND FULLY DIMMABLE DOWN TO 10% MINIMUM OR AS INDICATED IN LUMINAIRE SCHEDULE.
5. CERTIFICATION – UL LISTED FOR WET LOCATION, ROHS COMPLIANT. COMPLIES WITH IES LM79, LM80 AND TM21 TESTING STANDARDS.
6. MOUNTING – SURFACE MOUNTED WITH STAINLESS STEEL MOUNTING HARDWARE.
7. OPTIONS – VARIOUS PROFILES AND SHAPES. OPTIONAL UPLIGHT COMPONENT IF MOUNTED UNDER CANOPY.

## LED EXTERIOR WALL SCONCE

REVISED:

NOVEMBER 2020

LIGHTING PLATE:

XL-8